

The Director Specification

Furnish and install as an integral part of each Burner Mounted Panel, one (1) complete Director, Modular Graphic Burner Management System, as manufactured by Power Flame Incorporated. Each system shall be complete with an eight (8) color graphic display that will depict the burner and all major operation systems. Each annunciator package shall be complete with indicating lights: factory installed and pre-wired to a factory tested wiring harness. The wiring harness shall be complete with a quick disconnect feature that will allow the entire panel mounted display to be easily removed or replaced (via the Easy Access Panel Door), as required. The harness shall be of sufficient length so as to allow the display to be removed from the panel, without disconnection from the operating sources, in order to allow the operator full access to panel operating controls while viewing the operation of the graphic display. Signal lights shall be located on the specific operating feature for which they are to display, and an optional feature section shall be provided for the location of signal lights pertaining to features not graphically depicted on the Director Annunciation System. The annunciation features required shall be

List specifics required

Standard Configuration (see Director Bulletin)

And

Optional Features (see Optional Equipment Price Book)

The entire package shall be factory tested with the Power Flame Burner specified, and shall be shipped as one (1) integrated Burner/Annunciation System package.