

Power Flame Incorporated



SUGGESTED SPECIFICATION FOR MODEL JA(R) GAS BURNERS

THE POWER TO MANAGE ENERGY

2001 South 21st Street, Parsons, Kansas 67357

Telephone: 620-421-0480, Fax: 620-421-0948

Web Site: www.powerflame.com

E-Mail: CSD@powerflame.com

Suggested Specifications for Model JA(R)
Gas Burners

Table of Contents

<u>Section</u>	<u>Page(s)</u>
General Burner Description	1
Burner Control Panel	1
Gas Train.....	1
Mode of Operation.....	1
Product Liability Insurance.....	2
Burner Start Up Information and Test Data.....	2-3

**Suggested Specification for Model
JA(R) GAS BURNERS**

GENERAL BURNER DESCRIPTION

Furnish and install _____ Power Flame Model _____ forced draft flame retention natural gas burners. Each burner shall be capable of burning _____ CFH of _____ BTU/CU.FT. **(natural gas) or (propane gas)**, with a specific gravity of _____. Gas pressure supplied to the burner gas train supply connection shall be a minimum of _____ **(In. w.c.) (PSIG)** at full high rate and a maximum of _____ **(In. w.c.) (PSIG)** at static conditions.

Each burner shall be listed by Underwriters laboratories and shall bear the appropriate UL label. (In addition to the UL requirements, all equipment and installation procedures will meet the requirements of (IRI), (FM), (Other) _____ codes). Each burner shall be designed and constructed as an integrated combustion system package - and shall be factory fire tested.

Each burner shall be of welded steel construction and have a baked on powder coat finish. The firing head shall be of the multi port design and incorporate a stainless steel, flame retention diffusor. The burner combustion head will carry full five (5) year replacement warranty.

All air required for combustion shall be supplied by a blower, mounted integral to the burner. The blower wheel shall be of a forward curved "Squirrel Cage" design and shall be directly driven by a _____ HP, 3450 RPM _____ Volt, 60 Hertz _____ phase motor.

The burner ignition system shall be **(natural gas) or (propane gas)**. The pilot system components shall include spark ignited pilot assembly, 6000 Volt ignition transformer, pilot solenoid valve, pilot pressure regulator and manual gas shutoff cock. The flame proving system shall incorporate an Ultra-Violet detector.

BURNER CONTROL PANEL

All control components shall be mounted and wired within an integral burner mounted control panel. The panel shall incorporate an "Easy Access" (lift off) cover and will include Power On and Main Fuel indicating lights and an On/Off control switch.

GAS TRAIN

The gas train shall consist of a manual shutoff cock, main gas pressure regulator, main motorized gas valve, auxiliary solenoid gas valve, leak test cock and butterfly type gas flow control valve.

MODE OF OPERATION

Fuel/Air Control System

(Spec writer - select one of the following described systems 1 through 4).

1. On-Off Gas

The main gas supply shall be controlled by a diaphragm or solenoid valve. The air inlet control dampers shall be fixed at the optimum fuel/air ratio at the high fire position.

2. Low-High-Off Gas

The main gas supply shall be controlled by a motorized gas valve mechanically linked to air inlet control dampers which will provide a reduced fuel/air volume for low fire start and then mechanically open to the high fire run position. When the operating control is satisfied the burner will shutoff and return to the low fire start position.

3. Low-High-Low Gas

The main gas supply shall be controlled by a motorized gas valve mechanically linked to air inlet control dampers which will provide a reduced fuel/air volume for low fire start and then mechanically open to the high fire run position.

A Low-High-Low (temperature) (pressure) control shall electrically switch the burner to low or high fire position to best meet varying system load conditions. When the operating control is satisfied the burner shall shutoff and return to the low fire start position.

4. Modulation

The main On-Off gas supply shall be controlled by a diaphragm or solenoid valve. A modulating motor shall control the modulated positioning of the air inlet dampers, butterfly type gas proportioning valve to best meet varying system load conditions.

The positioning of the modulating motor shall be controlled by a 135 Ohm, or 4-20 milliamp, or 0-10 VDC, modulating type (temperature) (pressure) controller. When the operating control is satisfied the burner shall shutoff and return to the low fire start position. The modulating motor shall provide an electrical interlock to insure a guaranteed low fire start position prior to the pilot trial for ignition sequence.

5. (Spec writer - Use the following for all but modulating burners).

Gas flow shall be limited by a gas train mounted tee orifice assembly, which can be changed to suit job conditions without disconnecting the gas train

PRODUCT LIABILITY INSURANCE

The burner manufacturer will provide an insurance certificate documenting his current coverage of Product Liability Insurance with minimum coverage of \$10,000,000.

BURNER START UP INFORMATION AND TEST DATA

On completion of the burner system start up - the installing contractor will complete the attached "Burner Start Up and Test Data" form and deliver to the Specifying Engineer.

BURNER START UP INFORMATION & TEST DATA

The following information shall be recorded for each burner start up:

Power Flame Model _____ Invoice No. _____ Serial No. _____
 Installation Name _____ Start Up Date _____
 Start Up Contractors Name _____ Phone _____
 Name of Technician doing Start Up _____
 Type of Gas: Nat. LP Other Fuel Oil Grade No. _____

Gas Firing

Gas Pressure at Train Inlet

Burner in Off Position _____

Gas Pressure at Train Inlet

Low Fire _____ " W.C.

High Fire _____ " W.C.

Gas Pressure at Firing Head

Low Fire _____ " W.C.

High Fire _____ " W.C.

Gas Pressure at Pilot Test Tee

_____ " W.C.

Power Supply

Volts _____ Ph _____ Hz _____

Control Circuit Volts _____

Blower Motor amps at high fire _____

Flame Signal Readings

Pilot _____ D.C. Volts

Low Fire _____ D.C. Volts

High Fire _____ D.C. Volts

CO₂ or O₂ (Specify)

Low Fire _____ %

High Fire _____ %

CO

Low Fire _____ %

High Fire _____ %

Input Rate BTU/HR

Low Fire _____

High Fire _____

Over Fire Draft

Low Fire _____ " W.C.

High Fire _____ " W.C.

Stack Outlet Test Draft

Low Fire _____ " W.C.

High Fire _____ " W.C.

Net Stack Temperature

Low Fire _____ °F

High Fire _____ °F

Combustion Efficiency

Low Fire _____ %

High Fire _____ %

Air Inlet Damper Opening High Fire

Top _____ in.

Bottom _____ in.

Control Settings

General

Operating control cut out setting _____

Limit control cut out setting _____

Low gas pressure switch _____ in.

High gas pressure switch _____ in.

Operating control cut in setting _____

Limit control cut in setting _____

Operation Checklist

Checked For Proper Operation Of:

	<u>Yes</u>	<u>No</u>		<u>Yes</u>	<u>No</u>
Low water cut off	_____	_____	Barometric damper	_____	_____
High water cut off	_____	_____	Boiler room combustion air &	_____	_____
Flame safeguard control ignition failure	_____	_____	ventilation provision correct	_____	_____
Flame safeguard control main flame failure	_____	_____	Oil tank vent system correct	_____	_____
Burner air flow switch	_____	_____	All oil lines checked for leaks	_____	_____
Induced draft fan controls	_____	_____	All gas lines checked for leaks	_____	_____
Over fire draft controls	_____	_____	Gas lines & controls properly vented	_____	_____
Fresh air damper end switch	_____	_____	Other system components (specify)	_____	_____

Notified _____ of the following system deficiencies: _____
